



3933 US ROUTE 11, CORTLAND, NEW YORK 13045
 Phone Number: 1-800-345-3851 Fax Number: 607-758-3648

REPORT OF TEST

Panduit Corporation
 10500 167th Street
 Orland Park, IL 60467

The products described in this Report were tested for compliance to the standard(s) listed below. The products listed below are not part of an Intertek Verification Program and the results are provided to the client as a one time performance test.

Reference Intertek Report No.: 103096770CRT-001

Date: July 17, 2017

Test:

Electrical performance testing of a cabling configuration to the requirements of ANSI/TIA-568-C.2 for Category 6A channel.



Component Id	Manufacturer	Description	Part number
1	Panduit	Equipment Cord	NK6APC5M
2	Panduit	Outlet	NK6X88M
3	Panduit	Zone Cord	UXJPBU15
4	General Cable	U/UTP Plenum Horizontal Cable	GenSPEED 10000
5	Panduit	Cross Connect	NK6APC2M
6	Panduit	Equipment Cord	NK6APC3M

Standard and sections used:

ANSI/TIA-568-C.2-2009: Balanced Twisted-Pair Telecommunications Cabling and Components Standards, dated August 2009 (Sections 6.2.1 to 6.2.26)

Conclusion:

The channel cabling configuration, as described above, was tested in accordance with the ANSI/TIA-568-C.2-2009 standard, and did comply with the indicated applicable transmission requirements. The testing was performed at Intertek located in Cortland, New York.

Reviewed and approved by:

David Ayers
 Technician
 Global Cabling Products Testing

Antoine Pelletier
 Project Engineer
 Global Cabling Products Testing

This report is for the exclusive use of Intertek's Client and is provided pursuant to the agreement between Intertek and its Client. Intertek's responsibility and liability are limited to the terms and conditions of the agreement. Intertek assumes no liability to any party, other than to the Client in accordance with the agreement, for any loss, expense or damage occasioned by the use of this report. Only the Client is authorized to copy or distribute this report and then only in its entirety. Any use of the Intertek name or one of its marks for the sale or advertisement of the tested material, product or service must first be approved in writing by Intertek. The observations and test results in this report are relevant only to the sample tested. This report by itself does not imply that the material, product, or service is or has ever been under an Intertek certification program.